



## OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of  
NSF/ANSI Standard 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on May 21, 2012.

**Puregen Technology, Inc.**  
5423 G Street  
Chino, CA 91710  
909-548-0339

Facility: Taichung, Taiwan

### Mechanical Plumbing Devices

Faucets [1] [G]

FLR-133 (XX) (YY)	FLR-522 (XX) (YY)	FLR-606 (XX) (YY)	FLR-663 (XX) (YY)	FLR-828 (XX) (YY)
FLR-868 (XX) (YY)				

[1] (XX) Represents color finish: AW, AB, BG, BN, BB, CP, IY, ORB, RD, SN, W  
(YY) Represents air gap: (AG) - with air gap, (Blank) - without air gap

[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's  
Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193.  
Weighted average lead content  $\leq 0.25\%$ ; Solder and flux lead content  $\leq 0.2\%$ .